

## **ORDER OF AN EXECUTIVE OFFICER Boil Water Order**

**To:** Camp B'nai Brith Society  
"the Owner"

Stacy Shaikin  
"the Director"

**RE:** The Drinking Water Supply located in Pine Lake, Alberta and municipally described as:  
Camp B.B. Riback, SE 07-36-24 W4

**WHEREAS** I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted drinking water supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The water supply serving Camp B.B. Riback may be unsafe for human consumption.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. The water supply serving Camp B.B. Riback may be unsafe for human consumption due to three consecutive unsatisfactory bacteriological water sample results (collected on August 1<sup>st</sup>, 8<sup>th</sup> and 14<sup>th</sup>, 2023) confirming the presence of Total Coliforms. This is in contravention of the Nuisance and General Sanitation Regulation Section 11, which states "Where a person provided a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable".

**AND WHEREAS** by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

**NOW THEREFORE**, I hereby **ORDER** and **DIRECT**:

1. That the Owner and Director immediately issues a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. That the Owner and Director immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
  - a. Advise all affected users of this well water supply, that water used for drinking, making infant formula, juices, making ice, washing fruits and vegetables, or brushing teeth, must be boiled for at least 1 minute prior to use.

- b. Flush and disinfect thoroughly the water lines in the distribution system.
  - c. Submit two consecutive bacteriological water samples, collected at least 24 hours apart, that do not show the presence of Total Coliforms or E. coli bacteria.
3. The work referred to in paragraph 2 shall be completed immediately.
4. That, until such time as the work referred to in paragraph 2 is completed to the satisfaction of the undersigned, or an Executive Officer of Alberta Health Services, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Red Deer, Alberta, August 16, 2023.

Confirmation of a verbal order issued to Stacy Shaikin on August 16, 2023.

Executive Officer  
Alberta Health Services

You have the right to appeal

A person who      a) is directly affected by a decision of a Regional Health Authority, and  
                              b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board  
c/o Central Reception  
Main Floor, ATB Place North Tower  
10025 Jasper Avenue NW  
Edmonton, Alberta, T5J 1S6  
Phone: 780-222-5186  
Fax: 780-422-0914  
Email: [HealthAppealBoard@gov.ab.ca](mailto:HealthAppealBoard@gov.ab.ca)  
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

**Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>**

Template revised September 12, 2022