

ORDER OF AN EXECUTIVE OFFICER NOTICE OF CLOSURE

To: Canalta Real Estate Services Ltd.
“the Owner”

RE: The “pool” located in Camrose, Alberta and municipally described as:
Canalta Camrose – Swimming Pool, 4710 73 Street

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The bacteriological water sample collected on April 2, 2024, April 9, 2024, and April 16, 2024, had a heterotrophic plate count of 1060 CFU/mL, 260 CFU/mL, and 390 CFU/mL respectively.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Public Swimming Pools Regulation, Alberta Regulation 204/2014 and the Pool Standards there under exist in and about the above noted premises, namely:

- a. The bacteriological water sample collected on April 2, 2024, April 9, 2024, and April 16, 2024, had a heterotrophic plate count of 1060 CFU/mL, 260 CFU/mL, and 390 CFU/mL respectively. This is in contravention of Section 6.1 of the Alberta Health Pool Standards, which states: “The quality of water in a swimming pool must be maintained so that the water does not: a) have a heterotrophic plate count greater than 100 colony forming units per milliliter in a 100 milliliter sample.”

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately close the above noted premises.
2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Treat the swimming pool to eliminate any possible sources of contamination.
 - b. Chemically balance the swimming pool water.
 - c. Submit a bacteriological water sample from the swimming pool to the Provincial Laboratory, as a satisfactory water sample is required prior to re-opening the swimming pool.

3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Wetaskiwin, Alberta, April 19, 2024

Confirmation of a verbal order issued to Carlos and Girlie on April 19, 2024.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Wetaskiwin • Wetaskiwin Community Health Centre • Environmental Public Health

5610 40 Avenue, Wetaskiwin, Alberta, Canada T9A 3E4

<https://www.ahs.ca/eph>