

ORDER OF AN EXECUTIVE OFFICER

To: Adoor V Venkataramanan
"the Owner"

RE: Those housing premises located in Calgary, Alberta and municipally described as:
228 Canter Place SW

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The plumbing under the kitchen sink was leaking into the cabinet below.
- b. There was evidence of water leaking from the hot tub into the basement.
- c. The wall adjacent to the spiral staircase was in disrepair; the paint was lifting.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. The plumbing under the kitchen sink was leaking into the cabinet below. This is in contravention of section IV(6)(c) of the Minimum Housing and Health Standards which states that: All plumbing fixtures shall be serviceable, free from leaks, trapped and vented to the outside.
- b. There was evidence of water leaking from the hot tub into the basement. This is in contravention of section IV(6)(c) of the Minimum Housing and Health Standards which states that: All plumbing fixtures shall be serviceable, free from leaks, trapped and vented to the outside.
- c. The wall adjacent to the spiral staircase was in disrepair; the paint was lifting. This is in contravention of section III(5) of the Minimum Housing and Health Standards which states that: All walls shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Repair the plumbing under the kitchen sink to ensure it is no longer leaking.
 - b. Repair the plumbing for the hot tub to ensure it is no longer leaking.
 - c. Repair and refinish the wall next to the spiral staircase.
2. The work referred to in paragraph 1 shall be completed by **August 16, 2023**.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Calgary, Alberta, August 9, 2023

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Order of an Executive Officer

RE: Those premises located in Calgary, Alberta and municipally described as: 228 Canter Place SW

Page 3 of 3

Calgary • Southport Atrium • Environmental Public Health

10101 Southport Road SW, Calgary, AB Canada T2W 3N2

<https://www.ahs.ca/eph>