

ORDER OF AN EXECUTIVE OFFICER

To: ROSS ATLEY
"the Owner"

RE: Those housing premises located in Edmonton, Alberta and municipally described as:
Basement, 10150 159 Street NW

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The handrail was missing along the stairs to the basement.
- b. The basement bedroom window did not meet egress requirements.
- c. Wall finishes were in disrepair in areas throughout the basement, including the basement bathroom and other partially finished basement walls, and bathroom walls around the bathtub.
- d. There was a gap along the basement bathtub and the floor.
- e. Electrical outlets were hanging by wires and/or were missing cover plates throughout the basement.
- f. There was no operational smoke alarm installed in the basement bedroom area.
- g. Insect screens were missing from various windows.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. Item (g) is in contravention of section III(2)(b)(iii) of the Minimum Housing and Health Standards which states that: During the portion of the year when there is a need for protection against flies and other flying insects, every window or other device intended for ventilation shall be supplied with effective screens.
- b. Item (b) is in contravention of section III(3)(b) of the Minimum Housing and Health Standards which states that: (i) For buildings of 3 storeys or less and except where a bedroom door provides access directly to the exterior or the suite is sprinklered, each bedroom shall have at least one outside window which may be opened from the inside without the use of tools or special knowledge. (ii) Windows referred to in section 3(b)(i) shall provide unobstructed openings with areas not less than 0.35 m² (3.8ft²), with no dimension less than 380 mm (15"). (iii) If the window referred in section 3(b)(i) is provided with security bars, the security bars shall be installed so they may be opened from the inside without the use of any tools or special knowledge. (iv) Notwithstanding section 3(b)(i), (ii) and (iii), alternate provisions for emergency egress may be approved by an executive officer where, after consultation with a safety codes officer, the executive officer is satisfied that the alternate provisions provide for means of emergency egress.

- c. Item (a) is in contravention of section III(3)(c)(i) of the Minimum Housing and Health Standards which states that: Inside or outside stairs or porches including all treads, risers, supporting structural members, handrails, guards and balconies, shall be maintained in good repair and shall comply with the requirements of the Alberta Building Code or a Professional Engineer design.
- d. Items (c, d) are in contravention of section III(5) of the Minimum Housing and Health Standards which states that: All walls, windows, ceilings, floors, and floor coverings shall be maintained in good repair, free of cracks, holes, loose or lifting coverings and in a condition that renders it easy to clean. (a) Rooms containing a flush toilet and/or a bathtub or shower shall have walls and floors that are smooth, non-absorbent to moisture and easy to clean. All walls shall form a watertight joint with each other, the floor, the ceiling and where applicable with the bathtub or shower. (b) Rooms and sections of rooms that are used for food preparation and cooking shall have walls and floors constructed of materials which do not provide harbourage to dirt, grease, vermin and bacteria and that are easily kept clean.
- e. Item (e) is in contravention of section IV(11) of the Minimum Housing and Health Standards which states that: Every housing premises shall be supplied with electrical service. Outlets, switches and fixtures shall be properly installed and shall be maintained in a good and safe working condition.
- f. Item (f) is in contravention of section IV(1s) of the Minimum Housing and Health Standards which states that: Smoke alarms within dwellings shall be installed between each sleeping area and the remainder of the suite and, where hallways serve the sleeping areas; the smoke alarms shall be installed within the hallway. (a) Smoke alarms shall be operational and in good repair at all times.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Ensure that all openable windows are supplied with insect screens during the portion of the year when there are flies and other flying insects.
 - b. Install a handrail along the stairs to the basement, in accordance with the Alberta Building Code.
 - c. Ensure that all rooms used for sleeping have a window that provides an unobstructed opening with areas not less than 0.35 m² (3.8ft²), with no dimension less than 380 mm (15"), which may be opened from the inside without the use of tools or special knowledge.
 - d. Ensure that all basement finishes are in good repair, including the bathroom finishes.
 - e. Ensure that the electrical service is in good repair, including outlets, switches and fixtures.
 - f. Ensure that an operational smoke alarm is installed between the sleeping area and the remainder of the suite.

2. The work referred to in paragraph 1 shall be completed by following dates:
 - a. Item (f) to be completed by May 19, 2021
 - b. Item (b) to be completed by May 24, 2021
 - c. Items (a, d, e) to be completed by June 14, 2021
 - d. Item (c) to be completed by July 19, 2021, with documentation such as window order to be provided to this office by May 31, 2021

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Edmonton, Alberta, May 17, 2021

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised Feb 20, 2020

Order of an Executive Officer

RE: Those premises located in Edmonton, Alberta and municipally described as: Basement, 10150 159 Street NW

Page 4 of 4

Edmonton • 106 Street Tower • Environmental Public Health

700, 10055 – 106 Street, NW, Province, Canada, T5J 2Y2

www.albertahealthservices.ca/eph.asp