

ORDER OF AN EXECUTIVE OFFICER

To: 2329402 Alberta Inc.
"the Owner"

Roman Bouz
"the Owner"

Emanuel Paulo Ferreira
"the Owner"

Salvador Villanueva
"the Owner"

RE: Those housing premises located in Edmonton, Alberta and municipally described as:
10868 92 Street NW

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. There was a drainage pipe in the basement that was actively leaking wastewater from the house.
- b. The main floor toilet was not in proper working order.
- c. There were no smoke alarms noted in the house.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. Condition [a, b] were in contravention of section IV(6)(a) of the Minimum Housing and Health Standards which states that: Every housing premises shall be connected to the public sewage system, or to an approved private sewage disposal system. (a) The plumbing system and the sanitary drainage system or private sewage disposal system, as the case may be, including drains, fixtures, traps, vents, stacks, waste disposal facilities, pumpout sewage holding tanks, septic tanks and the disposal system shall be maintained in a proper operating condition.
- b. Condition [c] was in contravention of section IV(12) of the Minimum Housing and Health Standards which states that: Smoke alarms within dwellings shall be installed between each sleeping area and the remainder of the suite and, where hallways serve the sleeping areas; the smoke alarms shall be installed within the hallway. (a) Smoke alarms shall be operational and in good repair at all times.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Hire a qualified plumbing contractor to repair the leaking drainage pipe in the basement and the main floor toilet. **Provide documentation to this office.**
 - b. Install a working smoke alarm in the hallway outside each sleeping area. Ensure smoke alarms are maintained in proper operating condition and are located between sleeping spaces and the remainder of the house, wherever possible.

2. The work referred to in paragraph 1 shall be completed by May 31, 2023

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Edmonton, Alberta, May 25, 2023

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Template revised October 13, 2022

Edmonton • Environmental Public Health

Suite 700, 10055 – 106 Street NW, Edmonton, AB T5J2Y2

www.albertahealthservices.ca/eph.asp